



A1= Supply cooling, $\varnothing 0.47 \times 0.039$ " (Cu)
 A2= Return cooling, $\varnothing 0.47 \times 0.039$ " (Cu)
 B1= Supply heating, $\varnothing 0.47 \times 0.039$ " (Cu)
 B2= Return heating, $\varnothing 0.47 \times 0.039$ " (Cu)
 C= Air duct $\varnothing 4.92$ " ID.

Var	W/ L	Order code
1	23.3	592
2	23.5	598
3	23.7	603
4	24.3	617
5	24.5	623
6	25.3	642
7	26.3	667
8	23.0	584

*Use Var 3 for Nomial 24" ceiling grid