



- A1= Supply cooling, $\varnothing 0.47 \times 0.039$ " (Cu)
- A2= Return cooling, $\varnothing 0.47 \times 0.039$ " (Cu)
- B1= Supply heating, $\varnothing 0.47 \times 0.039$ " (Cu)
- B2= Return heating, $\varnothing 0.47 \times 0.039$ " (Cu)
- C= Air duct $\varnothing 4.92$ ", ID.

Var	W	L	Order code
1	23.3	46.9	1192
2	23.5	47.2	1198
3	23.7	47.8	1213
4	24.3	48.9	1242
5	24.5	49.1	1248
6	25.3	50.9	1292
7	26.3	52.8	1342
8	23.0	46.6	1184

* Use Var 3 for Nominal 24" ceiling grid